

Facility Summary in PRAIRIE County in the City of TERRY

Location: FARMERS UNION OIL CO TERRY
101 MCDONALD AVE
TERRY, MT 59349 PRAIRIE

Sys Fac ID: 40-06797

Last Inspected On: 1/3/2014

Operating Permit Renewal Date: 3/14/2017

Contact: Jimmie Rittal, (406) 637-5479

Owners/Operators: Farmers Union Oil Co Circle, Owner (406)-485-3475 PO BOX 460
CIRCLE MT 59215-0460

Larry Keltner, UST Class A Operator
Glenn Pehl, UST Class A Operator
Jeffrey P Schaefer, UST Class A Operator
Larry Kwasney, UST Class B Operator
Glenn Pehl, UST Class B Operator
Jeffrey P Schaefer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	25	4/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
955			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/3/2014	Stat. Inventory Reconciliation	Deferred	
1,000					
7	25	4/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
956			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/3/2014	Stat. Inventory Reconciliation	Deferred	
1,000					
8	25	4/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
957			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/3/2014	Stat. Inventory Reconciliation	Deferred	
560					

Facility Summary in PRAIRIE County in the City of TERRY

Location: 4 CORNERS
3 TEN MILE ROAD
TERRY, MT 59349 PRAIRIE

Sys Fac ID: 40-06798

Last Inspected On: 4/8/2015

Operating Permit Renewal Date: 8/3/2018

Contact: Leann Lantis, (406) 635-2198

Owners/Operators: Leann Lantis, Owner/Operator (406)-635-2198 PO BOX 332
TERRY MT 59349
Robert Waylon, Owner/Operator (406)-635-5814 PO BOX 332
TERRY MT 59349
Leann Lantis, UST Class A Operator
Leann Lantis, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	01	10/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5539		10/24/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	
10	01	10/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5540		10/24/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	
11	01	10/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5541		10/24/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	

Facility Summary in PRAIRIE County in the City of TERRY

Location: MTD PETROLEUM SERVICE LLC
14 TEN MILE RD
TERRY, MT 59349 PRAIRIE

Sys Fac ID: 56-14149

Last Inspected On: 12/29/2014

Operating Permit Renewal Date: 2/24/2018

Contact: Mark Underberg, (406) 951-0888

Owners/Operators: Cross Petroleum Services Glendive, Owner (406)-377-8325 PO BOX 1388
GLENDIVE MT 59330-1388

Gregory Cross, UST Class A Operator
Timothy Fife, UST Class A Operator
RJ Serpe, UST Class A Operator
RJ Serpe, UST Class B Global Operator
Ron Serpe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	10	5/5/2005	Concrete	Flexible Plastic	
5040	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	10	5/5/2005	Concrete	Flexible Plastic	
4960	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	10	5/5/2005	Concrete	Flexible Plastic	
4961	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
4	10	5/5/2005	Concrete	Flexible Plastic	
4962	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in PRAIRIE County in the City of TERRY

Location: MTD PETROLEUM SERVICE LLC
14 TEN MILE RD
TERRY, MT 59349 PRAIRIE

Sys Fac ID: 56-14149

Last Inspected On: 12/29/2014

Operating Permit Renewal Date: 2/24/2018

Contact: Mark Underberg, (406) 951-0888

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	10	5/5/2005	Concrete	Flexible Plastic	
5039	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	